

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7300-1004:0112

Page 1 of 1

CATEGORY: 7300 -- MISC. DEVICE/CONTROL UNIT ACCESSORIES

LISTEE: AIR PRODUCTS AND CONTROLS INC, 1749 E HIGHWOOD, PONTIAC, MI 48340
Contact: Richard Steele (248) 332-3900 Fax (248) 332-8807
Email: rsteele@ap-c.com

DESIGN: Models MSR-100R/W, MSR-100R/R, MSR-100R/S, MSR-100RS/W/C, MSR-100RS/W/O, MSR-100RS/R/C, MSR-100RS/R/O, MSR-100RS/S/C, and MSR-100RS/S/O smoke detector accessories. Refer to listee's data sheet for detailed product description and operational considerations.

RATING:

INSTALLATION: In accordance with listee's printed installation instruction, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, electrical rating and UL label.

APPROVAL: Listed as smoke detector accessories for use with listee's separately listed compatible RW Series, SM-501 Series and SL-2000 Series duct smoke detectors. Refer to listee's Installation Instruction Manual for details.

NOTE:

08-04-2005



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **July 01, 2010**

Listing Expires **June 30, 2011**

Authorized By: **FRANCIS MATEO**, Program Coordinator
Fire Engineering Division